

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

ES Products, Inc. P.O. Box 810 Bristol, R.I. 02809

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: ES Products, Inc. Roofing Fasteners

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

Stepa 1/4/14

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 12-0619.08 and consists of pages 1 through 12. The submitted documentation was reviewed by Alex Tigera.

MIAMI-DADE COUNTY
APPROVED

NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14

Page 1 of 12

ROOFING COMPONENT APPROVAL

<u>Category:</u> Roofing

Sub-Category: Roofing Fastener

Material: Steel

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT

FASTENERS:

Product	<u>Dimensions</u>	<u>Test</u> <u>Specifications</u>	Product Description
FM-245 and FM -245V	1.2" wide x 2.4" long x 1.226" tall	TAS 114 TAS 117	One piece base ply fasteners with a pair of dual gripping shanks, are formed from 0.013 in. thick G-90 hot dipped galvanized steel. Only the cap (head) on the fastener is coated on both sides with a black urethane coating. For use in NVS concrete and various poured gypsum decks. FM-245V includes a V-shaped notch on the bottom of the shanks (stems).
FM-260 and FM-260 V	1.2" wide x 2.4" long x 1.729" tall	TAS 114 TAS 117	One piece base ply fasteners with a pair of dual gripping shanks, are formed from 0.013 in. thick G-90 hot dipped galvanized steel. Only the cap (head) of the fastener is coated on both sides with a black urethane coating. For use in lightweight insulating concrete and various poured gypsum decks. FM-260V includes a V-shaped notch on the bottom of the shanks (stems).
FM-275 and FM-275V	2.46" wide x 3.59" long x 1.16" tall	TAS 114 TAS 117	Two piece factory preassembled base ply fastener/plate with dual gripping shanks and integral rib reinforced Galvalume stress distribution plate, formed from 0.013 in. thick G-90 hot dipped galvanized steel. Only the cap (head) of the fastener is coated on both sides with a black urethane coating. For use in NVS concrete and various poured gypsum decks. FM-275V includes a V-shaped notch on the bottom of the shanks (stems).



NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 2 of 12

FASTENERS:

TASTERERS.			
Product	Dimensions	<u>Test</u> Specifications	Product Description
FM-290 and FM-290V	2.46" wide x 3.59" long x 1.665" tall	TAS 114 TAS 117	Two piece factory preassembled base ply fastener/plate unit with a pair of dual gripping shanks and integral rib reinforced Galvalume stress distribution plate, formed from 0.013 in. thick G-90 hot dipped galvanized steel. Only the cap (head) of the fastener is coated on both sides with a black urethane coating. For use in lightweight insulating concrete decks and various poured gypsum decks. FM-290V includes a V-shaped notch on the bottom of the shanks (stems).
FM-75 and FM-75V	2.7" head x 1.2" long	TAS 114 TAS 117	Two piece factory preassembled base ply fastener/plate unit with dual gripping shanks and integral rib reinforced Galvalume stress distribution plate, formed from 0.013 in. thick G-90 hot dipped galvanized steel. Only the cap (head) of the fastener is coated on both sides with a black urethane coating. For use in NVS concrete and various poured gypsum decks. FM-75V includes a V-shaped notch on the bottom of the shanks (stems).
FM-90 and FM-90V	2.7" head x 1.7" long	TAS 114 TAS 117	Two piece factory preassembled base ply fastener/plate unit with dual gripping shanks and integral rib reinforced Galvalume stress distribution plate, formed from 0.013 in. thick G-90 hot dipped galvanized steel. Only the cap (head) of the fastener is coated on both sides with a black urethane coating. For use in lightweight insulating concrete decks and various poured gypsum decks. FM-90V includes a V-shaped notch on the bottom of the shanks (stems).
Insuldeck Loc-Nail Assembled Base Ply Fastener	2.7" head x 1-7/8" long	TAS 114 TAS 117	Two piece factory preassembled fastener/plate unit for use in cementitious wood fiber decks. Fastener formed from .024" thick AZ-55 hot dipped Galvalume steel. A 2.7" diameter disk formed from .013" AZ-55 Galvalume steel is factory.



NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 3 of 12

FASTENERS:

TASTENERS.			
Product	<u>Dimensions</u>	<u>Test</u> Specifications	Product Description
Twin Loc-Nail	2.7" head x 1.4" long, 2.7" head x 1.8" long, 2.7" head x 2.8" long, 2.7" head x 3.8" long, 2.7" head x 4.8" long	TAS 114 TAS 117	Three piece factory preassembled fastener/plate unit. Tube formed from .030" thick G-90 hot dipped galvanized steel. A 2.7" diameter disk formed from .018" AZ-55 Galvalume steel is factory assembled to each fastener. Locking staple formed from .080" coated steel is factory assembled into tube. For base ply attachment to new or existing cementitious wood fiber, poured gypsum and lightweight insulating concrete decks.
Twin Loc-Nail (no plate)	1.4" long, 1.8" long, 2.8" long, 3.8" long, 4.8" long	TAS 114 TAS 117	Two piece factory assembled fastener. Tube formed from .030" thick G-90 hot dipped galvanized steel. Locking staple formed from .080" coated steel is factory assembled into tube. For base ply attachment to new or existing cementitious wood fiber, poured gypsum and lightweight insulating concrete decks. Used with straight line batten bar.
Do-All Loc-Nail	.435" head x 1.4" long .435" head x 1.75" long		One-piece stainless steel fasteners for shingle attachment to gypsum board, gypsum plank, plywood, wood, and composite decks.
Tin Tag	1.625" round stress plate with or without .235" diameter central hole		Steel bearing stress plate, coated with AZ-55 Galvalume or G-90 galvanized for use with roofing nails or Do-All Loc-Nails (w/.235" central hole) to attach underlayment or base sheet.
Straight Line Batten Bar	1" wide x 0.040" thick x 100' long Galvalume (comes with barbs or no barbs surrounding the hole.	TAS 114 TAS 117	Batten Bar for mechanical attachment of membrane.
Low Pro Batten Bar	1" wide x .040" thick x 100' long Galvalume (comes with barbs or no barbs surrounding the hole)	TAS 114 TAS 117	Batten Bar for the mechanical attachment of membrane.
Deep Well Batten Bar	1" wide x .040" thick x 100' long Galvalume (comes with barbs or no barbs surrounding the hole)	TAS 114 TAS 117	Batten Bar for the mechanical attachment of membrane.
Seam Plate	2" round Galvalume stress plate		Preliminary attachment only, not to be used in wind load calculations.



NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 4 of 12

MANUFACTURING LOCATION:

1. Bristol, R.I.

EVIDENCE SUBMITTED:

Test Agency/Identifier	<u>Name</u>	Report	<u>Date</u>
Trinity ERD	Withdrawal Performance		
3	TAS 117(A) & (B)	#EO8950.04.08	04/17/08
	TAS 117 (A & B)	E41800.10.12	10/18/12
Factory Mutual Research	Wind Uplift	J.I. 0R0Q1.AM	03/22/91
Corporation	Wind Uplift	J.I. 1V1A9.AM	07/12/91
-	Standard 4470	J.I. 0V8A3.AM	11/13/91
	Standard 4470	J.I. 1V9A8.AM	02/25/92
	Wind Uplift	J.I. 0W2A0.AM	03/19/92
	Wind Uplift	J.I. 1W5A2.AM	10/05/92
	Wind Uplift	J.I. 0W4A1.AM	01/04/93
	Corrosion Resistance	J.I. 0W4A1.AM	01/07/93
	Testing of Loc-Nails		
	Standard 4470	J.I. 3W3A5.AM	01/27/94
	Corrosion Resistance	3031797	05/19/08
Trinity Engineering, Inc.	Dynamic Pull Through TAS 117(B)	#4670.10.95-1	10/01/95
Exterior Research & Design, LLC.	TAS 117(A), (B) & (C)	#4670.07.97-1	07/20/97
PRI Construction Materials Technologies	TAS 114	ESP-001-02-01	01/23/12 02/20/12



TYPICAL PROPERTIES:

Note: A 2 to 1 margin of saftey has been applied to test results producing the design values noted herein.

Withdrawal Resistance Performance - TAS 117(A) - Static Load						
<u>Fastener</u>	<u>Deck Type</u>	Static Withdrawal Resistance (lbf)				
FM-245 series & FM-275 series	Poured gypsum	30	0.0			
FM-260 series & FM-290 series	Min. 200 psi cellular Lightweight concrete	3 day cure 44.0	28 day cure 82.0			
FM-75 series	Poured gypsum	30.0				
FM-90 series	Min. 200 psi cellular Lightweight concrete	3 day cure 32.1	28 day cure 53.5			
	Min. 200 psi aggregate lightweight concrete	3 day cure 39.9	28 day cure 77.3			
Insuldeck Loc-Nail	Cementitious wood fiber	31.8				
Twin Loc-Nail	Poured gypsum	<u>131.35</u>				
Twin Loc-Nail	Cementitious wood fiber	17	6.2			

Withdrawal Resistance Performance - TAS 117(A) - Pulsating Load					
Fastener Deck Type		Static Withdrawal Resistance (lbf)			
FM-245 series & FM-275 series	Poured gypsum	25.8			
FM-260 series & FM-290 series	Min. 200 psi cellular lightweight concrete	28 day cure - 65			
FM-75 series	Poured gypsum	25.8			
FM-90 series	Min. 200 psi cellular lightweight concrete	28 day cure – 42.9			
	Min. 200 psi aggregate lightweight concrete	28 day cure – 66.3			
Insuldeck Loc-Nail	Cementitious wood fiber	20.8			
Twin Loc-Nail	Poured gypsum	<u>98</u>			
Twin Loc-Nail	Cementitious wood fiber	105.0			



NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 6 of 12

Base Sheet Rupture Performance, TAS 117(B): 2.5" x 3.6" Plate - FM-275 or FM-290 Manuf. Manuf. Base Rupture Base Rupture Value (lbf) Sheet Value (lbf) **Sheet** Certainteed Glassbase 128 **Polyglass** Elastobase V 156 Flex-I-Glas Base 134 PolyProtector UDL 97 PolySMS Base 186 Elastobase V (poly 88 surface) PRS Flintlastic SA Nailbase 78 Derbi Base 130 147 Firestone SBS Base Sheet 163 **Siplast** Parabase APP 160 182 Soprema Modified Sopra G 127 SBS Glass Torch Base 128 Soprabase 117 SBS Poly Torch Base 173 Tamko Glass-Base 133 **GAF** GAFGLAS #75 131 Vapor Chan 136 GAFGLAS Stratavent Easy Base 93 131 Tarco Eliminator

Tremco

US Ply

WP

Hickman

BURMastic Glass Ply

Duraflex 30 SBS Base

Vapor Chan

USP Base

USP NVB

Multi-Ply Glass

Multi-Ply Glass CL

Pika Ply HI-TEC 60

Performance Ply

142

231

144

132

140

146

212

191

230

99

82

140

226

137

124

153



GAFGLAS #80 Ultima

Liberty MA Base

HPR Tri Base Plus

HPR Glas Base

Permaply #28

Ventsulation

Dynabase

Garland

Johns

Manville

NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 7 of 12

Base Sheet Rupture Performance, TAS 117(B): 2.7" FM-30 Plate (FM-75 or FM-90) or Insuldeck Loc-Nail Manuf. Base Rupture Manuf. Base Rupture Sheet Value (lbf) Sheet Value (lbf) Glass Fiber Base 103 Honeywell 84 Johns Glasbase Sheet Manville Vented Base Sheet 85 104 Dynabase 95 Channel Vent GB Ventsulation 109 Celotex 92 Vaporbar GB **Siplast** Parabase 101 102 Parabase Plus 100 Hydrostop Firestone MB Base 88 Soprema Sopra-G 103 103 **GAF** GAFGLAS #75 Elastophene 180 107 89 Stratavent Sopralene 180 115 99 CertainTeed Flex-I-Glas Base 106 Tamko Nail Fast PolySMS Versa Base 106 111 Glass Fiber Base **Koppers** 108 Tremco **BURmastic Glass Ply** 114 Organic Base 94 **BURmastic Composite** 114 Ply #501 U.S. Intec Ultra Base 95.0 Malarkey 110 #602 107 Flex Base 111 #603 114 Modified Base 111 #605 109 117 Permavent Multi Ply NBS G-2 Base 102 W.P 112 Nord Hickman Nordstar Base 110 Performance Ply 113 Pika Ply SS-2 116



NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 8 of 12

Base Sheet Rupture Performance, TAS 117(B): FM-260 and FM-260V					
Manuf.	<u>Base</u> <u>Sheet</u>	Rupture Value (lbf)	Manuf.	Base Sheet	Rupture Value (lbf)
Black Warrior	Modified Arrowbase	91.15	Siplast	Irex 30	77.65
CertainTeed	Flexiglas FR Base	121.6	Soprema	Elastophene 180 Sanded	159.3
	PolySMS Base	99.3		Soprafix	93.35
	UltraPolySMS Base	116.25		Soprabase	60.9
Firestone	APP160	114.62	Tamko	Versa Base	50.8
	SBS Base Sheet	95	Tremco	BURmastic Composite Ply	78.85
	SBS Glass Torch	98.8	US Intec	Flex Base 60	92.95
	SBS Poly Torch	160.6		Modified Base 190P	101.95
	SBS PolyBase	149.25	US Ply	DuraFlex 30 SBS Base	95.25
	SBS Premium Base	123.7		DuraFlex SBS PolyBase	110.9
	SBS Smooth	125.95	W.P. Hickman	Multi-Ply Glass CL	92.35
GAF MC	GAFGlass #80 Ultima	97.2		Performance Ply	132.3
Garland	Tribase	92.3		Pika Ply HI-TEC 60	151.15
P.R.S.	Derbibase	71.2		Pika Ply HI-TEC 60 Type II	205.4
Polyglass	Elastobase V	69.2			
	Polyprotector UDL	50.95			

Base Sheet Rupture Performance, TAS 117(B): 2.7" Head						
Twin Loc-Nail						
Manuf.	Base Sheet	Rupture Value (lbs.)	Manuf.	Base Sheet	Rupture Value (lbs.)	
Honeywell	Black Armor base Sheet	109	Johns Manville	Dynabase	151	
Bitec	Beta Base	120	Johns Manville	Vestulation	114	
CertainTeed	Glasbase	90	Johns Manville	Perma Ply-28	138	
Certainteed	Flex-I-Glas Base	120	Siplast	Parabase	109	
CertainTeed	Flex-I-Glas All Weather Empire Base	125	Siplast	Parabase Plus	140	
Firestone	MB Base	128	Soprema	Sopra-G	123	
GAF	GAFGLAS Stratavent	119	Soprema	Modified Sopra-G	103	
GAF	GAFGLAS Stratavent perforated	97	Tamko	Glass-Base	117	
GAF	GAFGLAS #75	117	Tamko	Vapor-Chan	158	
WP Hickman	Multiply glass	133	Tamko	Base-N-Ply	103	
WP Hickman	Multiply glass CL	191				



NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 9 of 12

APPROVED APPLICATIONS:

Trade Name: FM-260 Series Base Sheet Fastener

Deck: Approved minimum 200-psi aggregate or cellular lightweight concrete. See lightweight

concrete deck Notice of Acceptance for Approved deck systems.

Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and

Approved attachment patterns.

Trade Name: FM-275 Series Base Sheet Fastener

Deck: Approved NVS lightweight concrete, various poured gypsums, and existing gypsum. See

lightweight concrete deck Notice of Acceptance for Approved deck systems.

Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and

approved attachment patterns.

Trade Name: FM-290 Series Base Sheet Fastener

Deck: Approved minimum 200-psi aggregate or cellular lightweight concrete. See lightweight

concrete deck Notice of Acceptance for Approved deck systems.

Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and

approved attachment patterns.

Trade Name: FM-75 Series Assembled Base Sheet Fastener

Deck: Approved NVS lightweight concrete, various poured gypsums, existing gypsum. See

lightweight concrete deck Notice of Acceptance for Approved deck systems.

Compatible Plate(s): N/A

Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and

approved attachment patterns.

Trade Name: FM-90 Assembled Base Sheet Fastener

Deck: Approved minimum 200-psi aggregate or cellular lightweight concrete. See lightweight

concrete deck Notice of Acceptance for Approved deck systems.

Compatible Plate(s): N/A

Application: FM-90 Base Ply Fastener is an approved and acceptable alternate to the Olympic Assembled

CR 1.7" Base Sheet Fastener. FM-90 Base Ply Fasteners may be used in any approved Roof Assembly NOA where the Olympic Assembled CR 1.7" Base Sheet Fastener is referenced. Approved fastening patterns and densities listed in any approved Roof Assembly NOA containing the Olympic Assembled CR 1.7" Base Sheet Fastener shall be acceptable when

using FM-90 Base Ply Fasteners.



NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 10 of 12 Trade Name: Insuldeck Loc-Nail Assembled Base Sheet Fastener

Deck: Cementitious Wood Fiber.

Compatible Plate(s): N/A

Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and

approved attachment patterns.

Trade Name: Twin Loc-Nail Assembled Base Sheet/Insulation Fastener

Deck: New or sound existing Cementitious Wood Fiber, Poured Gypsum, Lightweight Concrete.

Compatible Plate(s): N/A

Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and

approved attachment patterns.

Trade Name: Twin Loc-Nail (no plate) Base Sheet Fastener

Deck: New or sound existing Cementitious Wood Fiber, Poured Gypsum, Lightweight Concrete.

Compatible Plate(s): Straight Line Batten Bar.

Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and

approved attachment patterns.

Trade Name: Do-All Loc-Nail

Deck: Gypsum Board, Gypsum Plank, Plywood, Wood, and Composite Decks.

Compatible Plate(s): Tin Tab with .235" central hole.

Application: Shingle attachment (no plate), Base sheet/underlayment attachment (with plate).

Trade Name: Straight Line, Low Pro, Deep Well Batten Bars

Deck: Lightweight Insulating Concrete, Cementitious Wood Fiber, Gypsum, Gypsum Board,

Gypsum Plank, Plywood, Wood, and Composite Decks.

Insulation Types: Polyisocyanurate, Perlite, Fiberglass, Gypsum Board, High Density Wood Fiber, Composite.

Compatible Plate(s): N/A

Application: Mechanical attachment of membrane

Trade Name: Seam Plate

Deck: Lightweight Insulating Concrete, Cementitious Wood Fiber, Gypsum, Gypsum Board,

Gypsum Plank, Plywood, Wood, and Composite Decks.

Insulation Types: Polyisocyanurate, Perlite, Fiberglass, Gypsum Board, High Density Wood Fiber, Composite.

Compatible Plate(s): N/A

Application: Preliminary attachment only, not to be used in wind calculations.



NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 11 of 12

GENERAL LIMITATIONS:

- 1. Refer to Assembly Notices of Acceptance for use, density and attachment patterns.
- **2.** Fasteners shall be installed in accordance with manufacturer's published installation instructions.
- **3.** Care shall be taken not to puncture or tear the base sheet or insulation facer during fastener installation. Application recommendations are noted in Roofing Application Standard RAS 117.
- **4.** ES Product's fasteners are a component part of a Miami-Dade Approved Roof Assembly. These products are approved for use only with those roof assemblies listing these products as an approved component. Refer to an approved Roof Assemblies Notices of Acceptance for use, density and attachment patterns.
- 5. Any modifications to this Notice of Acceptance shall void such approval.
- **6.** All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
- 7. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.





NOA No 13-1106.02 Expiration Date: 04/17/18 Approval Date: 04/24/14 Page 12 of 12